



FOR CENTRAL OFFICE USE ONLY	ESTABLISHMENT NUMBER
-----------------------------	----------------------

Establishment Name Super 8		Name <input checked="" type="checkbox"/> Owner <input type="checkbox"/> General Manager Jay Patel	
Physical Address 310 S. Story		City Charleston	Zip 63834
Mailing Address Same		City	Zip
County 133	This inspection is a(n) <input type="checkbox"/> Initial <input checked="" type="checkbox"/> Annual <input type="checkbox"/> Follow-up	Telephone 573-427-2004	No. of Stories 1
		No. of Rooms 60	Is the current lodging license displayed? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A- new

Rooms Inspected: 103, 105, 107, 110, 114, 225, 208, 207, 221, 262	Water Supply <input type="checkbox"/> Private <input checked="" type="checkbox"/> Public Water sample taken <input type="checkbox"/> Yes <input type="checkbox"/> No	Wastewater <input type="checkbox"/> Private <input checked="" type="checkbox"/> Public Regulated by: <input type="checkbox"/> DHSS <input type="checkbox"/> DNR
Swimming Pools/Spas (check all that apply) Indoor pool <input type="checkbox"/> Outdoor pool <input type="checkbox"/> Spa <input type="checkbox"/> Pool larger than 2000 square feet <input type="checkbox"/>		

Please check if the following local ordinances apply	New Lodging Establishments <input type="checkbox"/> N/A
<input type="checkbox"/> Fire Safety <input type="checkbox"/> Electrical Wiring	Smoke detectors hardwired <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
<input type="checkbox"/> Plumbing	Fire alarm system installed <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
<input type="checkbox"/> Swimming Pools/Spas	Sprinkler system installed <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
<input type="checkbox"/> Fuel Burning Appliances	Swimming Pool Certified <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	Building Certified to National Standards or Occupancy Permit <input type="checkbox"/> Yes <input type="checkbox"/> No
	Historical Building <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A

Based on an inspection this day, the items marked "Out" below identify noncompliance in operations or facilities which must be corrected prior to issuance or renewal of your lodging license. Failure to comply with any time limits for corrections specified in this notice may result in revocation of your lodging license and/or prosecution. Owners may request a hearing before the Department Director upon filing a written request within ten days after receipt of this notice. (RSMo 315.005-065, 19 CSR 20-3.050)

	In=In Compliance	Out=Not In Compliance, explain on additional page(s)	NO=Not Observed	N/A=Not Applicable
Section A & B: Water Supply & Wastewater				
1. Approved source, construction and operation	X			
2. Complies with water quality standards	X			
3. Chlorinator maintained and operated properly				X
4. Wastewater operation and maintenance	X			
Section C: Sanitation/Housekeeping				
1. Walls, floors and ceilings in good repair		X		
2. Housekeeping practices and furnishings		X		
3. Towels and bed linens clean		X		
4. Mattresses and box springs clean	X			
5. Pest control procedures		X		
6. Ice machines, scoops, liners clean & protected	X			
7. Garbage storage and disposal	X			
8. Premises maintained, plant growth controlled		X		
Food Inspection conducted according to 19CSR20-1.025				
9. Food, equipment and single service/use	X			
10. Food protected from contamination	X			
11. Facilities to wash, rinse and sanitize	X			
12. Handwashing facilities/hygienic practices	X			
Section D: Life Safety				
1. Combustible/toxic items usage and storage	X			
2. Building maintained to assure safe conditions		X		
3. CO detectors hardwired, installed, good repair	X			
4. GFCI, outlets & switches installed, good repair		X		
5. Exit signs installed, good repair	X			
6. Emergency lighting installed, good repair	X			
7. Electric panel protected, labeled, good repair	X			
Required Annual Third Party Inspections				
1. Fire Alarm System	X			
2. Sprinkler System				X
3. Local Fire and Building Codes/Ordinances	X			
4. Current Boiler/Pressure Vessels MDPS Certification	X			
5. Backflow Device(s) Test			X	
6. Liquid Propane Leak Test			X	
Section E: Fire Safety				
1. Textiles, hangings and mirrors			X	
2. Fire extinguisher type, inspected, and location			X	
3. Vertical openings fire-rated, self-closing			X	
4. Doors, self-closing and fire-rated			X	
5. Smoke detectors hardwired, installed, good repair			X	
6. Evacuation route and plan, installed, available			X	
7. Stairs and ramps, maintained, storage			X	
8. Means of egress, number, maintained			X	
9. Handrails and balconies maintained and appropriate			X	
Section F: Swimming Pools/Spas				
1. Fence, gate adequate, proper closure mechanism		X		
2. Boundary line, pool depth properly marked				X
3. Deck is clean and in good repair				X
4. Lifesaving equipment adequate, good repair				X
5. Pool clarity, pH, disinfectant, & temp. maintained				X
6. Steps, ladders, and handrails installed, good repair				X
7. Adequate ventilation				X
8. Electrical outlets, proper protection & distance				X
9. Records maintained and signs posted				X
10. First aid kit available				X
11. Lighting adequate and in good repair				X
Section G: Plumbing/Mechanical				
1. Equipment adequate, good repair			X	
2. Ventilation adequate, plumbing, restrooms			X	
3. T & P relief valves adequate, good repair			X	
4. Relief valve discharge pipes installed, adequate			X	
5. Backflow, air gaps, no cross connections			X	
Section H: Heating & Cooling				
1. Unvented fuel-burning appliance/space heater		X		
2. Fire resistant room or sprinkler head		X		
3. Location of heating/cooling units		X		
4. Ventilation of appliances and utility rooms		X		
5. Operation and condition adequate		X		

INSPECTED BY (PRINT NAME and SIGN) Jodie Marcum Jodie Marcum	EPHS NUMBER 1681	AGENCY Miss. Co. Health	TELEPHONE 573-683-2191
LICENSING YEAR 20 22 120 23	APPROVED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	DATE INSPECTED 5-27-2022	FOLLOW UP DATE 6-16-2022
RECEIVED BY (PRINT NAME AND TITLE and SIGN) Mike Front Desk			PAGE 1 OF 2



Establishment Name	Physical Address	City
Section Reference	Observations, comments, and corrective measures	
C-5	Room 105 Light visible under outer door so pests aren't being prevented from entering.	
C-2	Room 101 Mold in bathroom by toilet	
C-5	Room 110 Light visible under outer door	
C-3	Room 114 Bedskirt on right bed is soiled/stained	
C-1	Room 208 Paint chipping on wall above couch	
C-5	Room 201 Light visible on outer door	
D-4	Room 202 GFCI won't reset Room 221 gm	
C-8	Trash in walk way by first building and in parking lot	
C-5	Doors in building one don't properly seal to prevent entry of pests. (doors by ice machine and room 108)	
D-2	Room 221 Door handle not properly functioning and won't open from inside.	
INSPECTED BY	RECEIVED BY	DATE
Jodie Marcum		5-27-2022